

Castle Hill Wastewater Treatment Plant

2018-19 Pollution monitoring yearly limit summaries



EPL 1725

Summary period: 01-07-2018 to 30-06-2019

Date published: 09-09-2019

Licensee: Sydney Water Corporation

PO Box 399

PARRAMATTA NSW 2124

50 percentile yearly summary								
EPA Point 5 Site code CH0005		Point description: In the channel between the tertiary filters and the disinfection facilities						
pollutant	unit of measure	sampling frequency	number of samples	minimum result	maximum result	50 percentile limit	50 percentile value	within limits
carbonaceous biochemical oxygen demand	mg/L	every 6 days	61	<2	6	7	<2	yes
nitrogen (ammonia)	mg/L	every 6 days	61	0.01	5.89	1	0.06	yes
nitrogen (total)	mg/L	every 6 days	61	9.31	21.8	20	16.6	yes
phosphorus (total)	mg/L	every 6 days	61	0.02	0.5	0.3	0.12	yes
total suspended solids	mg/L	every 6 days	61	<2	6	7	<2	yes

Castle Hill Wastewater Treatment Plant

2018-19 Pollution monitoring yearly limit summaries



EPL 1725

Summary period: 01-07-2018 to 30-06-2019

Date published: 09-09-2019

Licensee: Sydney Water Corporation

PO Box 399

PARRAMATTA NSW 2124

90 percentile yearly summary								
EPA Point 5 Site code CH0005	Point description: In the channel between the tertiary filters and the disinfection facilities							
pollutant	unit of measure	sampling frequency	number of samples	minimum result	maximum result	90 percentile limit	90 percentile value	within limits
aluminium	ug/L	monthly	12	41	299	6,400	214	yes
cadmium	ug/L	monthly	12	<0.1	<0.1	9.8	<0.1	yes
carbonaceous biochemical oxygen demand	mg/L	every 6 days	61	<2	6	10	<2	yes
cobalt	ug/L	monthly	12	0.2	0.7	4.2	0.6	yes
copper	ug/L	monthly	12	4.4	12.3	89	8.6	yes
diazinon	ug/L	monthly	12	<0.1	<0.1	1.5	<0.1	yes
iron	ug/L	monthly	12	24	61	3,000	55	yes
nitrogen (ammonia)	mg/L	every 6 days	61	0.01	5.89	5	0.77	yes
nitrogen (total)	mg/L	every 6 days	61	9.31	21.8	25	19.8	yes
phosphorus (total)	mg/L	every 6 days	61	0.02	0.5	1	0.31	yes
total suspended solids	mg/L	every 6 days	61	<2	6	10	2	yes
zinc	ug/L	monthly	12	11	18	90	18	yes

Castle Hill Wastewater Treatment Plant

2018-19 Pollution monitoring yearly limit summaries



EPL 1725

Summary period: 01-07-2018 to 30-06-2019

Date published: 09-09-2019

Licensee: Sydney Water Corporation

PO Box 399

PARRAMATTA NSW 2124

Average yearly summary								
EPA Point 5 Site code CH0005		Point description: In the channel between the tertiary filters and the disinfection facilities						
pollutant	unit of measure	sampling frequency	number of samples	minimum result	maximum result	Average Limit	Average value	within limits
aluminium	ug/L	monthly	12	41	299	640	93	yes
cadmium	ug/L	monthly	12	<0.1	<0.1	0.5	<0.1	yes
cobalt	ug/L	monthly	12	0.2	0.7	1.4	0.3	yes
copper	ug/L	monthly	12	4.4	12.3	24	6	yes
diazinon	ug/L	monthly	12	<0.1	<0.1	0.3	<0.1	yes
iron	ug/L	monthly	12	24	61	360	35	yes
zinc	ug/L	monthly	12	11	18	40	14	yes

50 percentile yearly summary								
EPA Point 6 Site code CH0006		Point description: At the outlet from the STP disinfection facilities						
pollutant	unit of measure	sampling frequency	number of samples	minimum result	maximum result	50 percentile limit	50 percentile value	within limits
Ceriodaphnia dubia immobilisation (EC50)	% Effluent/Vol	monthly	12	100	100	50	100	yes

80 percentile yearly summary								
EPA Point 6 Site code CH0006		Point description: At the outlet from the STP disinfection facilities						
pollutant	unit of measure	sampling frequency	number of samples	minimum result	maximum result	80 percentile limit	80 percentile value	within limits
faecal coliforms	CFU/100mL	every 6 days	61	<1	59,000	200	24	yes

Castle Hill Wastewater Treatment Plant

2018-19 Pollution monitoring yearly limit summaries



EPL 1725

Summary period: 01-07-2018 to 30-06-2019

Date published: 09-09-2019

Licensee: Sydney Water Corporation

PO Box 399

PARRAMATTA NSW 2124

90 percentile yearly summary								
EPA Point 6 Site code CH0006		Point description: At the outlet from the STP disinfection facilities						
pollutant	unit of measure	sampling frequency	number of samples	minimum result	maximum result	90 percentile limit	90 percentile value	within limits
hydrogen sulphide (unionised)	ug/L	monthly	12	<30	<30	480	<30	yes

Average yearly summary								
EPA Point 6 Site code CH0006		Point description: At the outlet from the STP disinfection facilities						
pollutant	unit of measure	sampling frequency	number of samples	minimum result	maximum result	Average Limit	Average value	within limits
hydrogen sulphide (unionised)	ug/L	monthly	12	<30	<30	92	<30	yes