

Fairfield Wastewater Treatment Plant

February Pollution Monitoring Summary

EPL 372



Summary period: 01-02-2020 to 29-02-2020

Date obtained: 24-02-2020

Date published: 03-03-2020

Licensee: Sydney Water Corporation

PO Box 399

PARRAMATTA NSW 2124

Table 1: 100 percentile data

EPA Point 24 Site code FF0024 Overflow Point		Point description: Effluent channel			
pollutant	unit of measure	sampling frequency	100 percentile limit	100 percentile actual	within limits
carbonaceous biochemical oxygen demand	mg/L	on bypass	100	76	yes
total suspended solids	mg/L	on bypass	120	64	yes

Under Environment Protection Licence 372 conditions, as set by the NSW Environment Protection Authority, the 100 percentile limits are allowed to be exceeded during wet weather.

Table 2: Routine monitoring data

EPA Point 24 Site code FF0024 Overflow Point		Point description: Effluent channel				
pollutant	unit of measure	sampling frequency	number of samples	minimum results	mean results	maximum results
carbonaceous biochemical oxygen demand	mg/L	on bypass	7	16	42	76
faecal coliforms	CFU/100mL	on bypass	7	50,000	2369286	7,000,000
total suspended solids	mg/L	on bypass	7	18	42	64

Fairfield Wastewater Treatment Plant

September Pollution Monitoring Summary

EPL 372



Summary period: 01-09-2019 to 30-09-2019

Date obtained: 25-09-2019

Date published: 08-10-2019

Licensee: Sydney Water Corporation

PO Box 399

PARRAMATTA NSW 2124

Table 1: 100 percentile data

EPA Point 24 Site code FF0024 Overflow Point		Point description: Effluent channel			
pollutant	unit of measure	sampling frequency	100 percentile limit	100 percentile actual	within limits
carbonaceous biochemical oxygen demand	mg/L	on bypass	100	100	yes
total suspended solids	mg/L	on bypass	120	67	yes

Under Environment Protection Licence 372 conditions, as set by the NSW Environment Protection Authority, the 100 percentile limits are allowed to be exceeded during wet weather.

Table 2: Routine monitoring data

EPA Point 24 Site code FF0024 Overflow Point		Point description: Effluent channel				
pollutant	unit of measure	sampling frequency	number of samples	minimum results	mean results	maximum results
carbonaceous biochemical oxygen demand	mg/L	on bypass	2	64	82	100
faecal coliforms	CFU/100mL	on bypass	2	120	145060	290,000
total suspended solids	mg/L	on bypass	2	62	65	67