

# Winmalee Wastewater Treatment Plant

## 2016-17 Pollution monitoring yearly limit summaries



### EPL 1963

Summary period: 01-07-2016 to 30-06-2017

Date published: 11-08-2017

Licensee: Sydney Water Corporation

PO Box 399

PARRAMATTA NSW 2124

50 percentile yearly summary								
EPA Point 4 Site code WM0004		Point description: Downstream of the chamber prior to discharge						
pollutant	unit of measure	sampling frequency	number of samples	minimum result	maximum result	50 percentile limit	50 percentile value	within limits
carbonaceous biochemical oxygen demand	mg/L	every 6 days	61	<2	5	10	<2	yes
Ceriodaphnia dubia immobilisation (EC50)	% Effluent/Vol	monthly	12	>100	100	50	100	yes
nitrogen (ammonia)	mg/L	every 6 days	61	0.01	2.37	2	0.02	yes
nitrogen (total)	mg/L	every 6 days	61	5.23	9.83	10	6.68	yes
phosphorus (total)	mg/L	every 6 days	61	0.04	0.36	2	0.14	yes
total suspended solids	mg/L	every 6 days	61	<2	6	10	<2	yes

80 percentile yearly summary								
EPA Point 4 Site code WM0004		Point description: Downstream of the chamber prior to discharge						
pollutant	unit of measure	sampling frequency	number of samples	minimum result	maximum result	80 percentile limit	80 percentile value	within limits
faecal coliforms	CFU/100mL	every 6 days	61	<1	3,500	200	3	yes

# Winmalee Wastewater Treatment Plant

## 2016-17 Pollution monitoring yearly limit summaries



### EPL 1963

Summary period: 01-07-2016 to 30-06-2017

Date published: 11-08-2017

Licensee: Sydney Water Corporation

PO Box 399

PARRAMATTA NSW 2124

90 percentile yearly summary								
EPA Point 4 Site code WM0004		Point description: Downstream of the chamber prior to discharge						
pollutant	unit of measure	sampling frequency	number of samples	minimum result	maximum result	90 percentile limit	90 percentile value	within limits
aluminium	ug/L	monthly	12	<5	53	1,600	10	yes
carbonaceous biochemical oxygen demand	mg/L	every 6 days	61	<2	5	15	<2	yes
chlorine (total residual)	mg/L	every 6 days	61	<0.04	0.14	0.1	<0.04	yes
cobalt	ug/L	monthly	12	0.2	0.3	2.4	0.3	yes
copper	ug/L	monthly	12	3.1	6.4	160	5	yes
diazinon	ug/L	monthly	12	<0.1	<0.1	2.4	<0.1	yes
iron	ug/L	monthly	12	41	1,190	6,500	707	yes
nitrogen (ammonia)	mg/L	every 6 days	61	0.01	2.37	5	0.63	yes
nitrogen (total)	mg/L	every 6 days	61	5.23	9.83	15	8.1	yes
phosphorus (total)	mg/L	every 6 days	61	0.04	0.36	3	0.25	yes
total suspended solids	mg/L	every 6 days	61	<2	6	15	2	yes
zinc	ug/L	monthly	12	8	23	230	15	yes

# Winmalee Wastewater Treatment Plant

## 2016-17 Pollution monitoring yearly limit summaries



### EPL 1963

Summary period: 01-07-2016 to 30-06-2017

Date published: 11-08-2017

**Licensee:** Sydney Water Corporation

PO Box 399

PARRAMATTA NSW 2124

Average yearly summary								
EPA Point 4 Site code WM0004		Point description: Downstream of the chamber prior to discharge						
pollutant	unit of measure	sampling frequency	number of samples	minimum result	maximum result	Average Limit	Average value	within limits
aluminium	ug/L	monthly	12	<5	53	190	6.3	yes
cobalt	ug/L	monthly	12	0.2	0.3	1.6	0.3	yes
copper	ug/L	monthly	12	3.1	6.4	20	4	yes
diazinon	ug/L	monthly	12	<0.1	<0.1	0.3	<0.1	yes
iron	ug/L	monthly	12	41	1,190	830	411	yes
zinc	ug/L	monthly	12	8	23	40	11	yes