

Cascades Water Filtration Plant

January Pollution Monitoring Summary

EPL 4406



Summary period: 01-01-2021 to 31-01-2021
 Date obtained: 29-01-2021
 Date published: 12-02-2021

Licensee: Sydney Water Corporation
 PO Box 399
 PARRAMATTA NSW 2124

Table 1: 100 percentile data

EPA Point 1 Site code EFFQCA		Point description: End of the discharge pipe			
pollutant	unit of measure	sampling frequency	100 percentile limit	100 percentile actual	within limits
pH	pH Units	every 90 days	6.5 - 8.5	8.22	yes
total suspended solids	mg/L	every 90 days	30	<2	yes

100 percentile means that 100 % of samples (or all samples) taken must not exceed the limit for that pollutant.

Table 2: Routine monitoring data

EPA Point 1 Site code EFFQCA		Point description: End of the discharge pipe				
pollutant	unit of measure	sampling frequency	number of samples	minimum results	mean results	maximum results
aluminium	mg/L	every 90 days	1	-	-	0.01
chlorine (total residual)	mg/L	every 90 days	1	-	-	0.05
iron	mg/L	every 90 days	1	-	-	0.01
manganese	mg/L	every 90 days	1	-	-	<0.01
pH	pH Units	every 90 days	1	-	-	8.22
total dissolved solids	mg/L	every 90 days	1	-	-	182
total suspended solids	mg/L	every 90 days	1	-	-	<2

Average and percentile limits are only applied annually for routine monitoring data in Table 2.

Cascades Water Filtration Plant

October Pollution Monitoring Summary

EPL 4406



Summary period: 01-10-2020 to 31-10-2020

Date obtained: 26-10-2020

Date published: 06-11-2020

Licensee: Sydney Water Corporation

PO Box 399

PARRAMATTA NSW 2124

Table 1: 100 percentile data

EPA Point 1 Site code EFFQCA		Point description: End of the discharge pipe			
pollutant	unit of measure	sampling frequency	100 percentile limit	100 percentile actual	within limits
pH	pH Units	every 90 days	6.5 - 8.5	8.07	yes
total suspended solids	mg/L	every 90 days	30	<2	yes

100 percentile means that 100 % of samples (or all samples) taken must not exceed the limit for that pollutant.

Table 2: Routine monitoring data

EPA Point 1 Site code EFFQCA		Point description: End of the discharge pipe				
pollutant	unit of measure	sampling frequency	number of samples	minimum results	mean results	maximum results
aluminium	mg/L	every 90 days	1	-	-	0.02
chlorine (total residual)	mg/L	every 90 days	1	-	-	<0.04
iron	mg/L	every 90 days	1	-	-	0.06
manganese	mg/L	every 90 days	1	-	-	0.23
pH	pH Units	every 90 days	1	-	-	8.07
total dissolved solids	mg/L	every 90 days	1	-	-	370
total suspended solids	mg/L	every 90 days	1	-	-	<2

Average and percentile limits are only applied annually for routine monitoring data in Table 2.

Cascades Water Filtration Plant

July Pollution Monitoring Summary

EPL 4406



Summary period: 01-07-2020 to 31-07-2020
 Date obtained: 26-07-2020
 Date published: 06-08-2020

Licensee: Sydney Water Corporation
 PO Box 399
 PARRAMATTA NSW 2124

Table 1: 100 percentile data

EPA Point 1 Site code EFFQCA		Point description: End of the discharge pipe			
pollutant	unit of measure	sampling frequency	100 percentile limit	100 percentile actual	within limits
pH	pH Units	every 90 days	6.5 - 8.5	7.93	yes
total suspended solids	mg/L	every 90 days	30	<2	yes

100 percentile means that 100 % of samples (or all samples) taken must not exceed the limit for that pollutant.

Table 2: Routine monitoring data

EPA Point 1 Site code EFFQCA		Point description: End of the discharge pipe				
pollutant	unit of measure	sampling frequency	number of samples	minimum results	mean results	maximum results
aluminium	mg/L	every 90 days	1	-	-	0.01
chlorine (total residual)	mg/L	every 90 days	1	-	-	<0.04
iron	mg/L	every 90 days	1	-	-	<0.01
manganese	mg/L	every 90 days	1	-	-	<0.01
pH	pH Units	every 90 days	1	-	-	7.93
total dissolved solids	mg/L	every 90 days	1	-	-	125
total suspended solids	mg/L	every 90 days	1	-	-	<2

Average and percentile limits are only applied annually for routine monitoring data in Table 2.